



PROVIDE A SEPARATE NEUTRAL FOR ALL MULTI-WIRE LINE TO NEUTRAL LOADS. PROVIDE TRACER ON THE WHITE NEUTRAL WIRE THE SAME COLOR AS PHASE CONDUCTOR.

PROVIDE A SEPARATE NEUTRAL FOR ALL MULTI-WIRE LINE TO NEUTRAL LOADS. PROVIDE TRACER ON THE WHITE NEUTRAL WIRE THE SAME COLOR AS PHASE CONDUCTOR.  
\* ISOLATED GROUND CIRCUIT. PROVIDE ADDITIONAL GROUND WIRE WITH YELLOW TRACER



① SURGE SUPPRESSOR -  
PSP PRODUCTS MODEL #H2C200-04-N-C  
LIEBERT MODEL #LM100120YANCE  
G.E. DIGITAL ENERGY MODEL #T1PR7120Y1012S  
LOCATION OF SURGE SUPPRESSORS NOT SHOWN ON LAYOUT DRAWINGS. MOUNT AS RECOMMENDED BY MANUFACTURER.

1). SERVICE EQUIPMENT IN OTHER THAN DWELLING UNITS MUST BE LEGIBLY MARKED IN THE FIELD WITH THE AVAILABLE FAULT CURRENT. THE FIELD MARKING(S) MUST INCLUDE THE CALCULATION DATE AND BE OF SUFFICIENT DURABILITY TO WITHSTAND THE ENVIRONMENT.

1. EXPOSED LIVE PARTS ON ONE SIDE AND NO LIVE OR GROUNDED PARTS ON THE OTHER SIDE OF THE WORKING SPACE, OR EXPOSED LIVE PARTS ON BOTH SIDES EFFECTIVELY GUARDED BY SUITABLE WOOD OR OTHER INSULATING MATERIALS, INSULATED WIRE OR INSULATED BUSBARS OPERATING AT NOT OVER 300V SHALL NOT BE CONSIDERED LIVE PARTS.
2. EXPOSED LIVE PARTS ON ONE SIDE AND GROUNDED PARTS ON THE OTHER SIDE.
3. EXPOSED LIVE PARTS ON BOTH SIDES OF THE WORK SPACE (NOT GUARDED AS PROVIDED IN CONDITION 1) WITH THE OPERATOR BETWEEN,

